



State of Utah

GARY R. HERBERT
Governor

SPENCER J. COX
Lieutenant Governor

Department of Environmental Quality

Amanda Smith
Executive Director

DIVISION OF WATER QUALITY
Walter L. Baker, P.E.
Director

January 17, 2015

DIVISION OF WATER QUALITY UTAH DEPARTMENT OF ENVIRONMENTAL QUALITY PUBLIC NOTICE TO REISSUE A UPDES PERMIT

PURPOSE OF PUBLIC NOTICE

THE PURPOSE OF THIS PUBLIC NOTICE IS TO DECLARE THE STATE OF UTAH'S INTENTION TO REISSUE A UTAH POLLUTANT DISCHARGE ELIMINATION SYSTEM (UPDES) PERMIT UNDER AUTHORITY OF THE UTAH WATER POLLUTION CONTROL ACT, SECTION 19-5-104(9) AND 107(2), UTAH CODE ANNOTATED 1953, AS AMENDED. SAID "PERMIT" REFERS TO THE UPDES PERMIT AND THE FACT SHEET STATEMENT OF BASIS (INCLUDING TOTAL MAXIMUM DAILY LOADS (TMDL'S)) IF APPLICABLE, AS PER SECTION 303(D) OF THE FEDERAL CLEAN WATER ACT (CWA)].

PERMIT INFORMATION

PERMITTEE NAME:	Plain City Corporation
MAILING ADDRESS:	4160 West 2200 North, Plain City, UT 84404
TELEPHONE NUMBER:	801-645-0393
FACILITY LOCATION:	West of Ogden in Weber County
UPDES PERMIT NO.:	UT0021326
PERMITTED OUTFALLS	001
RECEIVING WATER:	Drainage ditch, Dix Creek, First Salt Creek, Harold S. Crane Waterfowl Management area and finally into Willard Spur of the Great Salt Lake

BACKGROUND

This facultative lagoon sewer system was built and came into operation in 1970 and serves the community of Plain City with a population of approximately 5,500 people, and is located west of Ogden in Weber County. The treatment facility consists of a comminutor, followed by a six cell facultative lagoon system with two primary cells and a total surface area of 35 acres. Disinfection is accomplished with chlorination that includes three concrete tanks that serve as mixing basins. A V-notch weir is at the outfall of the basins and is used to measure the flow. The Design flow is 1.75 million gallons a day (mgd) with a monthly maximum of 1.0 mgd.

PUBLIC COMMENTS

Public comments are invited any time prior to the deadline of the close of business on February 17, 2015. Written public comments can be submitted to: Ken Hoffman, UPDES Engineering Section, Utah Division of Water Quality, P.O. Box 144870, Salt Lake City, Utah 84114-4870 or by email at: kenhoffman@utah.gov. After considering public comment the Utah Division of Water Quality may execute the permit issuance, revise it, or abandon it.

The permit is available for public review under "Public Notices" at www.waterquality.utah.gov/. If internet access is not available, a copy may be obtained by calling Ken Hoffman at 801-536-4313.